



SERVICE CERTIFICATE

Unit 6, Seaview Industrial Estate, Horden, Peterlee, Co. Durham, SR8 4TQ
 Tel: +44 (0) 191 586 6633 Fax: +44 (0) 191 586 3555
 Website: www.peterleefire.co.uk Email: sales@peterleefire.co.uk



Date:	
Contact:	
INVOICE ADDRESS	
AS OVER	

Service Type:	
Telephone:	
LOCATION ADDRESS	
MANCHESTER & BUXTON LC	
GARDEN COTTAGE	
SECABY	
GAINFORD	
CO. DURHAM	
DL23HE	

INVOICE No	A/C REF	CONTRACT	SAGE	Engineer	DELIVERY/SERVICE DATE	CUSTOMER ORDER No	<input checked="" type="checkbox"/> Service <input type="checkbox"/> Call out
------------	---------	----------	------	----------	-----------------------	-------------------	---

DESCRIPTION	TOTAL SERVICED	COND	RECHARGED	REFURB	NEW EQUIP
3 LTR WATER ADDITIVE					
6 LTR WATER ADDITIVE					
WATER 6 LTR					
WATER 9 LTR					
CO2 2 KG					
CO2 5 KG					
CO2 OTHER					
FOAM AFFF 1 L					
FOAM AFFF 2 L					
FOAM AFFF 3 L					
FOAM AFFF 6 L					
FOAM AFFF 9 L					
3 LTR CLASS F					
6 LTR CLASS F					
POWDER 1 KG					
POWDER 2 KG					
POWDER 4 KG					
POWDER 6 KG					
POWDER 9 KG	30				
POWDER 12 KG					
TOTAL EXTINGUISHERS	30				
TOTAL FIRE BLANKETS					
TOTAL HOSE REELS					
ENGINEERS COMMENTS	APPLIANCES REMOVED NOTE No. RECOMMENDATION REPORT No.				

SPARE PARTS FITTED	QTY	O/S
HEADCAP ASSEMBLY - 19/55125		
HEADCAP SEAL - 19/55054	5	
HOSE/NOZZLE SEAL - 19/55054	30	
SAFETY CLIP/PIN - 57225P	2	
VALVE ASSY (CO2) - 47/51195		
HORN ASSY (CO2) - DHORN		
HOSE & HORN ASSY CO2 - 47/95001		
TAMPER INDICATOR - 19/50797	30	
GAUGE TEST - GTEST	30	
SEALING BAND - SBAND		
BURSTING DISC - SBDISC		
HOSE REEL NOZZLE - HRN19		
WORM DRIVE CLIP - SWCHP		
CARTRIDGE 55GM - 3144/00		
J BRACKET - B3001		
2 KG CO2 BRACKET - CB001		
EXTINGUISHER ID SIGN - SIGNS		
MISC. O. RINGS - 19/55054		
DISPOSAL OF EQUIPMENT - DISP		
EXTINGUISHER TESTED BY		
DISCHARGE - EXDIS		
ATTENDANCE FEE		
CALL OUT FEE - CALL		
DELIVERY CHARGE - CARRIDGE		
APPLIANCES FIXED - EXAPPL		
LABOUR - LABOUR		
MIN CHARGE		

Engineer's Signature	No.	Print Name	Date Signed
<i>[Signature]</i>	30	<i>[Signature]</i>	27/11/05
Customer's Signature			
<i>[Signature]</i>			
Position			
Office Manager			

TOTAL	
TOTAL	
TOTAL	

Inpection by the user: It is recommended that regular visual inspections of all extinguishers be carried out by the user or by user's representative. The frequency of inspections by the user should be not less than monthly and, when circumstances require, inspections should be carried out more frequently. Apart from the non confirming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS5306: Part 3. Terms Subject to PETERLEE FIRE COMPANY Standard published conditions of sale, applicable to the goods or services described above. Copy available on request.

Customer Copy: White A/C: Green